

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3266-0057:002 Page 1 of 1

CATEGORY: Door Operators

LISTEE: Stanley, Rt. 6 & Hyde Rd., Farmington CT 06032
Contact: *Dean Negrelli (860) 679-6453

DESIGN: DURA-GLIDE 2000 and 3000 series. Model 3000 series consists of single or bi-parting electromechanical assembly and motor. Individual bi-parting leaves slide behind swinging sidelights. Single doors are bi-parting in opening widths of 36", 42", 44" and 48" with a nominal 82" height. Bi-parting doors are available in opening width 48", 60" and 72", with the same opening height. The swinging sidelights are equal in width to the respective sliding door leaf. Door and side lights constructed of 6063-T5 aluminum extrusions. Entire assembly, such as operating mechanism, doors, header, frame, etc., provide by listee. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door operator for use in exit locations where openings do not require fire-rating assemblies. Authority having jurisdiction should be consulted prior to installation.

NOTE: Formerly 3265-0057:002

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager